



„ITEM – Consult” Ltd
Notified Body for Gas Appliances and
Pressure Vessels and Equipments

CE1837

CERTIFICATE

**For “Module A2:INTERNAL PRODUCTION CONTROL PLUS
SUPERVISED PRESSURE EQUIPMENT CHECKS AT RANDOM
INTERVALS ”**


№: 1837-PED-0272

Manufacturer’s Company name and address:	ÜNL ÜSOY YAPI MALZEMELERI SANAYI VE TICARET LIMITED SİRKETİ“, Izmir–TURKEY
Productio site:	Izmir Pancar Organize Sanayi Bolgesi, 10. Cadde, №2 Torbali
Product:	Hot water Storage Tanks
Type Designation: (models/series)	ÜEB/T; ÜEB/ Ç; ÜEB/HP;ÜAT and ÜBT Stated on page 2
Max. admissible pressure (bar):	Stated on page 2
Max. permissible temperature (°C):	95
Category PED/2014/68/EU	I
Conformity Report №:	278/11.01.2023

The “ITEM-Consult” confirms that after carried out procedure “ Internal production control plus supervised pressure equipment checks at random intervals–module A2” the examined “Hot water Storage Tanks ÜEB/T; ÜEB/ Ç; ÜEB/; ÜAT and ÜBT”, fullfills the essential requirement of Directive 2014/68/EU, introduced by “Regulation of essential requirements and conformity assessment of pressure equipment”.Admit manufacturer to be in the right to affix the identification number 1837 of the Notified Body.

Validity: 12.01.2024

Sofia, Bulgaria.
13.01.2023
(Place and date of issue)



Manager “ITEM Consult”Ltd:
(Ing. L.Vasilev)



Type Designation:
(models/series)

ÜEB/T Single Serpentine Hot water Storage Tanks; PS = 10 bar

ÜEB/T-100, ÜEB/T-160, ÜEB/- 200, ÜEB/T-300, ÜEB/T-500, ÜEB/- 800, ÜEB/T-1000,
ÜEB/T-1500, ÜEB/T-2000, ÜEB/T-2500, ÜEB/T-3000, ÜEB/T-4000, ÜEB/T-5000

ÜEB/Ç Double Serpentine Hot Water Storage Tank; PS = 10 bar

ÜEB/Ç-160, ÜEB/Ç-200, ÜEB/Ç-300, ÜEB/Ç-500, ÜEB/Ç-800, ÜEB/Ç-1000, ÜEB/Ç-1500,
ÜEB/Ç-2000, ÜEB/Ç-2500, ÜEB/Ç-3000, ÜEB/Ç-4000, ÜEB/Ç-5000

ÜEB/HP for heat pumps; PS = 10 bar

ÜEB/HP-200, ÜEB/HP-300, ÜEB/HP-500, ÜEB/HP-800, ÜEB/HP-1000

ÜAT Accumulation Tanks; PS = 10 bar

ÜAT-100, ÜAT-160, ÜAT-200, ÜAT-300, ÜAT-500, ÜAT-800, ÜAT-1000, ÜAT1-500, ÜAT-
2000, ÜAT-3000, ÜAT-5000

ÜBT Buffer Tanks; PS = 6 bar

ÜBT-100, ÜBT-160, ÜBT-200, ÜBT-300, ÜBT-500, ÜBT-800, ÜBT-1000, ÜBT-1500,
ÜBT-2000

Sofia, Bulgaria, 13.01.2023
(Place and date of issue)



Manager "ITEM Consult" Ltd:

(Eng. L.Vasilev)